



- ① 1009.2 Headroom: Stairways shall have a minimum headroom clearance of 80"; it is now 14'.
- ② 1007: According to this section and 1007.6, 9 areas of refuge are required and should comply:
 - One wheelchair space of 30"x48" for each 200 occupants served.
 - Each area of refuge should be separated from the building by a smoke barrier as well as have direct access to an enclosed stairway.
- ③ 1008: According to this section, means of egress doors should be a minimum width of 32", a minimum height of 6'8", and should be side-hinged and swing in the direction of egress travel.
- ⑤ 1012: According to this section, handrails must be changed to comply:
 - Height must be between 34"-38"; is now 36".
 - Perimeter dimension of at least 4"-6.25" with a max cross section of 2.23"; is now 6"x2".
 - Handrail must extend horizontally at least 12" beyond the slope.

MEANS OF EGRESS

ASSIGNMENT 4A
PAGE: 3 OF 3

48-215 MATERIALS & ASSEMBLY
SPRING 2017

INSTRUCTOR: DAMIANI

SELENA ZHEN